

# CERTIFICATE

EU-Type examination – design type  
according to 2014/68/EU, module B

Manufacturer:	<b>ALPENTA s.r.o., Piletická 486, Věkoše, 503 41 Hradec Králové</b>
Pressure equipment:	Refrigeration equipment assemblies
Type series	EAC1-xxC(H,U,R,S) EAC2-xxC(H,U,R,S) EAC3-xxC(H,U,R,S) EAC4-xxC(H,U,R,S) EAC5-xxC(H,U,R,S) EAC6-xxC(H,U,R,S)
Operating data:	
Fluid / Fluid group	R410 or R134A / 2
Max. allowable pressure PS (bar):	44 (R410) 18 (R134A)
Max. allowable temperature TS (°C):	100
Volume ( L ):	10 - 80
Rated cooling capacity (kW):	20 - 400
Category:	I, II, III, IV

The design type has been tested and it is confirmed that satisfy requirements of Directive 2014/68/EU, that is transposed by Government Order No. 219/2016 Coll., as amended, according to Act No. 90/2016 Coll., as amended.

Basis of the certificate: Inspection Report No.: 174e1/20/7.6-PED

A list of the relevant parts of the technical documentation and the conditions of validity is given in the design type examination report.

Certificate Registration No.: 1420/20/PED/B

Valid until: 21. 09. 2030

Prague: 21. 09. 2020



On behalf of Notified Body Identification No. 1735: František Kozubík

TÜV AUSTRIA CZECH  
spol. s r.o.  
Zelený pruh 1560/99  
140 02 Praha 4–Braník  
E-mail:  
pha@tuvaustralia.cz  
<http://www.tuvaustralia.cz>

Notified Body 1735

Ing. František Kozubík

Mobile:  
+420 724 024 711  
E-mail:  
kozubik@tuvaustralia.cz

Deputy for Manager

Ing. Roman Váleček  
Mobile:  
+420 724 024 718  
E-mail:  
valecek@tuvaustralia.cz

Branch Offices:  
Praha,  
Brno,  
Ostrava,  
Hradec Králové

Bank Connection:  
Česká spořitelna, a.s.  
404822/0800

IČ: 26427753  
DIČ: CZ 26427753

Spis. zn.: C. 81469  
Městský soud v Praze